



# TECHNICAL LETTER

## Roofing Systems

717 17th St. Denver, CO 80202 (800) 922-5922

**Johns Manville**  
**Eric Olson**  
**Northeast Regional Service Manager**  
Roofing Systems Group  
10100 W Ute Ave  
Littleton, CO 80127  
303-978-2508  
Eric.Olson@jm.com

March 1, 2021

Subject: Facet – Roof Mount Attachment System

To Whom It May Concern:

This letter shall serve as a statement of compatibility between Johns Manville's (JM) water proofing membrane products and Sustainable Technologies' Facet – Roof Mount attachment systems, when selection of similar base material are utilized; example - JM TPO membrane with Facet Flashing made with JM TPO membrane. The similar chemistry of the membrane and flashing will have no adverse effect resulting in accelerated degradation.

Installation of the Facet – Roof Mount system will not void JM's issued warranty, provided it is installed by an approved JM roofing contractor. Prior to installing any photovoltaic energy system on a JM guaranteed roof system, and to ensure continued guarantee coverage, the required information and process outlined in the Johns Manville Peak Advantage Guarantee "Photovoltaic Overburden Additions on JM Guarantee Roof System" must be complete. This outline may be found on [www.JM.com](https://www.jm.com/content/dam/jm/global/en/commercial-roofing/Guarantees-Warranties/Guarantee%20Guidelines_PV_Overburden_FORM.pdf) via the following link: [https://www.jm.com/content/dam/jm/global/en/commercial-roofing/Guarantees-Warranties/Guarantee%20Guidelines\\_PV\\_Overburden\\_FORM.pdf](https://www.jm.com/content/dam/jm/global/en/commercial-roofing/Guarantees-Warranties/Guarantee%20Guidelines_PV_Overburden_FORM.pdf)

If you have any additional questions, please contact me at 303-978-2508.

Sincerely,

**Eric Olson**  
**Northeast Regional Services Manager**  
**Johns Manville**

*Johns Manville is a manufacturer of commercial roofing products and offers this general conceptual information to you as a courtesy. This complimentary assistance is not to be used or relied upon by anyone as a substitute for professional engineering design or documentation required by building code, contract or applicable law. By accepting these comments you agree they do not constitute any representations, endorsements of, or an assumption by Johns Manville of any liability for either the adequacy of the design of this building or of any material not supplied by Johns Manville. These comments are for Johns Manville Guarantee purposes only. Additional requirements may be necessary as determined by contract documents, building code and regulations, or governing entity.*