



TEST RESULTS 16ga CEE PURLIN	
UPLIFT	3733lbf
DRAG (ALONG PURLIN)	2198lbf

DISCLAIMER; THESE TEST WERE CONDUCTED ONLY EVALUATING THE CONNECTION BETWEEN THE S-5-CP AND THE CEE PURLIN. THIS DOES NOT TAKE INTO ACCOUNT ANY OTHER LOAD LIMITATIONS SUCH AS SPAN STRENGTH OR CONNECTION OF THE PURLIN TO THE STRUCTURE.

MATERIAL: 6000 AL & 300 SS		METAL ROOF INNOVATIONS, LTD. 12730 Black Forest Road COLORADO SPRINGS, CO 80908 888-825-3432	
EST ASSEMBLY WT:			
HARDWARE:	TITLE S-5-CP PURLIN CLAMP - W/ PVKIT		
	DRAWING NO.	DRAWN BY JM	DATE 9/16/25
	SCALE 1:5	FILE NAME	
S-5!® PRODUCTS ARE PROTECTED BY MULTIPLE U.S. AND FOREIGN PATENTS. VISIT OUR WEBSITE AT WWW.S-5.COM FOR COMPLETE INFORMATION ON PATENTS AND TRADEMARKS			