

SECTION 07 72 53

SNOW GUARDS

This section has been prepared by Metal Roof Innovations, Ltd. for use in the preparation of a project specification. Attachment may be by one of the following methods:

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
 - 1. Snow guards for metal roofs.
 - 2. Non-penetrating attachment system.

1.2 RELATED SECTIONS

- A. Division 01: Administrative, procedural and temporary work requirements apply to this section.
- B. Section 07 41 13 – Metal Roof Panels
- C. Section 07 61 00 – Sheet Metal Roofing
- D. Section 07 62 00 – Sheet Metal Flashing and Trim
- E. Section 07 72 53 – Roof Accessories – Snow Guards
- F. Section 13 34 19 – Metal Building Systems

1.3 REFERENCES

- A. Aluminum Association (AA) - Aluminum Standards and Data, Current Edition.
- B. ASTM International (ASTM):
 - 1. A484/A484M-16 – Standard Specifications for General Requirements for Stainless Steel Bars, Billets and Forgings.
 - 2. A554-16 – Standard Specification for Welded Stainless Steel Mechanical Tubing.
 - 3. A555/A555M-16 – Standard Specification for General Requirements for Stainless Steel Wire and Wire Rods.
 - 4. B85-03 - Standard Specification for Aluminum-Alloy Die Castings.
 - 5. B221-04a - Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles and Tubes.
 - 6. F836M-02 (Current) – Standard Specification for Style 1 Stainless Steel Metric Nuts (Metric).
 - 7. F880-12 – Standard Specification for Stainless Steel Socket, Square Head, Torx and Slotted Headless-Setscrews.
- C. ICC Evaluation Service (www.icc-es.org):
 - 1. Division: 05 00 00 – METALS; Section: 05 05 23 – METAL FASTENERS Evaluation Report ESR-3869.

1.4 SUBMITTALS

A. Action Submittal:

1. Shop Drawings: Include roof plans showing locations of snow guards on roof and attachment details and spacing.
2. Product Data:
 - a. Product description.
 - b. Construction details.
 - c. Material descriptions.
 - d. Individual component dimensions.
 - e. Finishes.
 - f. Installation instructions.
3. Samples:
 - a. Clamp samples.
 - b. 12-inch long cross member samples including all associated hardware.

B. Informational Submittals:

1. Proof of Job-Specific Engineering: Include registered professional engineer wet-stamped calculation for number and frequency of snow guard attachments based on design roof snow load, roof slope, roof dimensions, specific roof profile name, material type, gauge thickness and brand of manufacture; brand and model of snow retention device.
[(<https://s-5.com/snow-calculator/>)]
2. Proof of Product Testing: Results of appropriate product tensile load testing, issued by a recognized ISO 17025 accredited independent testing laboratory, showing the mean (of a minimum three test pulls) ultimate load-to-failure value of attachment **[bracket] [clamping device]** proposed on the specimen material named in B.1.
3. Proof of Certified Production: Copy of manufacturer current ISO 9001 certificate (latest edition).
4. Proof of Best Practice Compliance: Manufacturer duly executed letter stating full compliance with all provisions of the Metal Construction Association technical bulletin, "Qualifying Snow Retention Systems for Metal Roofing" (latest edition).

C. Closeout Submittals:

1. Certification: Installer's certification or duly executed letter stating snow guard system was installed in accordance with manufacturer's instructions and approved shop drawings.

1.5 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Manufacturer to specialize in production of snow guard products of the type specified with a minimum of 10 years documented experience.
- B. Manufactured in an ISO 9001 certified facility; ICC audited facility.
- C. Installer Qualifications: Installer to specialize in metal roof installation and installation of snow guard products with a minimum of 5 years documented experience.
- D. Mockup:
 1. Size: Minimum **[8] []** feet long.
 2. Show: Snow guard attachment, cross members and accessories.
 3. Locate **[where directed] []**.
 4. Approved mockup may remain as part of the Work.

- E. Warranty:
 - 1. Lifetime material/workmanship warranty on all products.
 - 2. System Performance warranty.

1.6 DELIVERY, STORAGE AND HANDLING

- A. Deliver components to jobsite properly packaged to provide protection during transport, delivery and handling.
- B. Store products in manufacturer's original labeled and unopened packaging in a clean and dry location, protected from potential damage, until ready for application.

PART 2 - PRODUCTS

2.1 SYSTEM DESCRIPTION

- A. Attachment system to provide attachment to standing seam metal roofs:
 - 1. With only minor dimpling of panel seams.
 - 2. Without penetrations through roof seams or panels.
 - 3. Without use of sealers or adhesives.
 - 4. Without violation of roof warranty.
- B. Performance Requirements: Provide snow guards to withstand exposure to the weather and environmental elements and resist design forces without failure due to defective material or manufacture.
 - 1. Loading: Design snow guard system to resist minimum design roof snow load(s) [of ___] [See **structural drawings for roof design snow loads**].
 - 2. Factor of Safety: Utilize a factor of safety \geq [2] [___] to determine allowable loads from ultimate tested [clamp] [bracket] tensile mean load values.
 - 3. Source Limitation: Provide snow guard system as designed and tested by the manufacturer as a complete system. Install all system components by the same manufacturer.

2.2 MANUFACTURER

- A. Basis of Design: S-5![®] div. of Metal Roof Innovations, Ltd., 500 W. Highway St., Iowa Park, TX 76367; Tel: 888-825-3432; Fax: 719-495-0045; Email: support@s-5.com; Web: www.s-5.com
- B. Acceptable Manufacturers if products meet specification requirements:
 - 1. S-5![®] div. of Metal Roof Innovations, Ltd. <https://www.s-5.com/>
 - 2. LMCurbs. <https://www.lmcurbs.com/>
 - 3. Rocky Mountain Snow Guards Inc. <https://www.rockymountainsnowguards.com/>
- C. Substitutions: [Under provisions in Division 1.] Not permitted.

2.4 CONTINUOUS, 1 INCH (25.4 MM) PIPE-TYPE SNOW RETENTION SYSTEMS FOR STANDING SEAM METAL ROOFS

Do not use S-5! Standard Clamps for the attachment of DualGard with the exception of the S-5-KHD.

- A. Basis of Design: DualGard[™], manufactured by S-5! div. of Metal Roof Innovations, Ltd.
- B. Components:
 - 1. Clamps
 - a. Manufactured from 6000-series aluminum extrusions conforming to ASTM B221 or aluminum castings conforming to ASTM B85 and to AA Aluminum Standards and Data.

- 1) Clamp model to be as recommended by the manufacturer for the specific seam profile used on the project.
 - 2) Setscrews: 300-series stainless steel, 18-8 alloy, 3/8 inch (9.525 mm) diameter, with round nose point.
 - 3) Attachment bolts: 300-series stainless steel, 18-8 alloy, 8 mm diameter, hex flange bolt.
2. Pipe Brackets:
- a. Manufactured from 5000-series alloy and temper aluminum conforming to ASTM B221 and AA Aluminum Standards and Data.
3. Pipe Couplings (Splices):
- a. Manufactured from 6000-series alloy and temper aluminum extrusions conforming to ASTM B221 and AA Aluminum Standards and Data.
4. Pipes (Cross Members):
- a. Manufactured from 6000-series alloy and temper aluminum extrusions conforming to ASTM B221 and AA Aluminum Standards and Data.
 - 1) Model: DualPipe™
5. Pipe Collar:
- a. Manufactured from 6000-series alloy and temper aluminum extrusions conforming to ASTM B221 and AA Aluminum Standards and data, with 1/4-20 x 3/8 inch (9.525 mm) stainless steel setscrew.
 - 1) Model: DualCollar™

Snow and ice clips are

6. Snow and Ice Clips:
- a. Aluminum, with rubber foot, minimum 3 inches (76.2 mm) wide.
 - 1) Model: DualClip™ II for standing seam heights 1 inch (25.4 mm) to 1.5 inches (38.1 mm).
 - 2) Model: DualClip III for standing seam heights 1.75 inches (44.45 mm) to 3.25 inches (82.55 mm).
7. End Caps:
- a. Metal, snap-in.

PART 3- EXECUTION

3.1 EXAMINATION

Prior to beginning installation, verify:

1. Panel seaming is complete.
2. Panel attachment is sufficient to withstand loads applied by snow guard system.
3. Installation will not impeded roof drainage.

3.2 PREPARATION

- A. Clean areas to receive attachments; remove loose and foreign matter that could interfere with installation or performance.

3.3 INSTALLATION

- A. Install system in accordance with manufacturer's current instructions and approved Shop Drawings.
- B. DualGard Snow Retention System:

1. Pre-assemble one S-5! Mini clamp to each pipe bracket assuring the setscrews are facing the correct side of the standing seam they will be applied to. Attach S-5! Mini clamps to pipe brackets on what will become the upslope side of the assembly. Hand tighten M8 bolt fastening S-5! Mini clamp to pipe bracket. Pre-load setscrews into clamps.
 - i.
2. Insert pipes into pre-assembled upslope pipe bracket and S-5! Mini clamp assemblies. Insert a pipe collar inside last bracket of either end of the run as pipe is inserted into brackets.
 - ii.
3. Place downslope clamps on standing seams at maximum 48 inches (1219 mm) on center or less as required by certified calculation.
 - iii.
4. Place downslope clamps in straight, aligned rows using a string line.
5. Some clamps are directional. Reference installation instructions for the specific clamp used to assure they are oriented correctly.
6. Tighten downslope clamp setscrews to manufacturers recommended torque. Test setscrew torque using calibrated torque wrench.
7. Attach pre-assembled upslope row of S-5! Mini clamps with attached pipe brackets and pipes aligning with downslope clamps. Tighten M8 bolt to fasten pre-assembly on downslope clamps to recommended torque of 156 inch pounds (13 foot pounds) (17.63 Newton meters).
8. Tighten upslope clamp setscrews to standing seams to manufacturers recommended torque. Test setscrew torque using calibrated torque wrench. Then, tighten M8 bolt on upslope clamps to recommended torque of 156 inch pounds (13 foot pounds) (17.63 Newton meters).
9. Install pipe coupling at adjoining pipe end joints. Insert coupling halfway into pipe that will be joined to next pipe in the run.
10. Cut extended end of pipe at end of run. Do not cantilever pipes more than 6 inches (152.4 mm) beyond last clamp and bracket at ends.
11. Apply end cap to each pipe.

Include the following when applicable. Use one DualClip per panel for panels up to and including 24 inch (609.9 mm) seam spacing and two per panel over 24 inches (609.6 mm).

12. Install **[one DualClip]** **[two DualClips]** per panel between panel seams.
 - a. DualClips: Secure **[DualClip II]** **[DualClip III]** to back side of cross member using stainless steel #10 x ½ inch (12.7 mm) screw.

END OF SECTION